





Review and SIGN & DATE 24/1/19	SUPERSEDES INVENTORY NO. 2443	संस्थान क्रय विनिर्देश (हीप : हरिद्वार) PLANT PURCHASE SPECIFICATION (HEEP: HARIDWAR)	HW12086
			मुख्य पृष्ठ PREFACE SHEET
<p align="center"> <u>BARE RECTANGULAR HOLLOW COPPER CONDUCTOR</u> </p> <p align="center"> केवल आंतरिक प्रयोग हेतु प्रदायक को देने से पूर्व इस मुख्य पृष्ठ को निकाल दें । FOR INTERNAL USE ONLY REMOVE THIS PREFACE BEFORE ISSUE TO SUPPLIERS. </p> <p> समतुल्य मानक / सूची आदि COMPARABLE STANDARDS / CATALOGUES ETC. </p> <p align="right"> } NIL </p> <p> सुझाए / सम्भावित प्रदायक एवं श्रेणी SUGGESTED / PROBABLE SUPPLIERS AND GRADES. </p> <p align="right"> } REGISTERED VENDORS OF PMD TG080 </p> <p> कोई अन्य जानकारी ANY OTHER INFORMATION </p> <p align="right"> } NIL </p>			
Copyright and Confidential The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in any way detrimental to the interest of the company.		संस्थान मानकीकरण समिति APPROVED : PLANT STANDARDIZATION COMMITTEE Gr. No: 288	
REV. NO. 5 DL 15-01-2019		PREPARED : EME ISSUED : TSX DATE: 02-03-1982	

SIGN & DATE SUPERSEDES INVENTORY NO.		संस्थान क्रय विनिर्देश (हीप : हरिद्वार) PLANT PURCHASE SPECIFICATION (HEEP: HARIDWAR)		HW12086 पृष्ठ 5 का 1 Page 1 of 5	
		<u>BARE RECTANGULAR HOLLOW COPPER CONDUCTOR</u>			
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in any way detrimental to the interest of the company.	1. GENERAL: This specification covers high conductivity soft copper conductors of hollow rectangular section for stator windings of Turbo-generators.				
	2. APPLICATION: Used for manufacturing of water cooled stator windings bus bars of turbo-generators.				
	3. COMPLIANCE WITH INTERNATIONAL STANDARD: This standard is based on BS EN 13600:2013 and BHEL experience.				
	4. DIMENSIONS AND TOLERANCES:				
	4.1 Dimensions & Permissible tolerances: According to figure-1 on Page 5.				
	4.2 Length of Profile: In straight length of 7000mm (Min. acceptable)				
4.3 The conductor shall have radiused corners, both inside and outside as figure-1 on Page 5.					
5. No joints shall be made in hollow copper conductor after it is drawn or extruded.					
6. CONDUCTOR:					
6.1 Conductor Material: The hollow copper conductor shall be made of copper of Cu-HCP (CW021A) grade as per BS EN 13600:2013 and chemical composition as per clause 8.1 of this specification.					
6.2 Freedom from defects: External and internal surface of the rectangular hollow copper conductor shall be bright, free from dirt and smooth without cracks, blisters and pits. The rectangular hollow copper conductor shall have shining surface free of doubling, cracks, chips, scabbing/scaling, metal dust and oxidation products. The inner surface of rectangular hollow copper conductor must be reasonably clean, degreased, free of copper pitting, copper chips, wrinkles and oxidation products on and directly below the surface.					
SIGN & DATE 24/1/19	TSX PSC Member QAX. AGREED DEPT.	D. LANGRISH R.K. Sharma Vishant NAME DATE & SIGNATURE Reaffirmed Year 2024 WKS BY R. K. Sharma 15-01-2019 29-7-24 TSX (EPR) 24-97	TRANSLATED BY WORKED BY CHECKED BY SUPERVISED BY	NAME SATENDER KUMAR AJAY KUMAR GUPTA A.K. GOYAL	SIGNATURE & DATE 15-1-19 15-1-19
INVENTORY NO. 2443	संस्थान मानकीकरण समिति APPROVED : PLANT STANDARDIZATION COMMITTEE PREPARED : EME ISSUED : TSX DATE : 02.03.1982				

SIGN & DATE SIGNATURE INVENTORY NO.		संस्थान क्रय विनिर्देश (हीप : हरिद्वार) PLANT PURCHASE SPECIFICATION (HEEP: HARIDWAR)		HW12086 पृष्ठ 5 का 2: Page 2 of 5														
		7. DEVIATION OF PROFILE ALIGNMENT: The broad side of tubing cannot curve inward (concave). An outward curved shape(convex) is permissible but is limited by the dimensional tolerances. The radii must be tangential to the rectangular tubing surface and must blend smoothly with these surfaces without any sharp corners. The allowable center line deviation is 10% of the wall thickness.																
SUPERSEDES INVENTORY NO.	8. PROPERTIES & TESTING 8.1 CHEMICAL COMPOSITION: The hollow copper conductor shall be manufactured from copper of Cu-HCP (CW021A) grade as per BS EN 13600:2013 with the following composition:																	
	<table border="1"> <thead> <tr> <th>Constituents</th> <th>Composition, in % by weights</th> </tr> </thead> <tbody> <tr> <td>Cu</td> <td>99.95^a Min.</td> </tr> <tr> <td>Bi</td> <td>Max. 0.0005</td> </tr> <tr> <td>P</td> <td>0.002 to 0.007</td> </tr> <tr> <td>O</td> <td>—^b</td> </tr> <tr> <td>Pb</td> <td>0.005</td> </tr> <tr> <td>Other elements</td> <td>Total 0.03 (excluding Ag, P)</td> </tr> </tbody> </table>					Constituents	Composition, in % by weights	Cu	99.95 ^a Min.	Bi	Max. 0.0005	P	0.002 to 0.007	O	— ^b	Pb	0.005	Other elements
Constituents	Composition, in % by weights																	
Cu	99.95 ^a Min.																	
Bi	Max. 0.0005																	
P	0.002 to 0.007																	
O	— ^b																	
Pb	0.005																	
Other elements	Total 0.03 (excluding Ag, P)																	
^a Including silver, up to a maximum of 0.015%. ^b The oxygen content shall be such that the material conforms to the hydrogen embrittlement requirements as per EN 1976. Hydrogen Embrittlement Test as per ISO 2626. NOTE: The total of other elements (excluding Cu, Ag, P) is defined as the sum of As, Bi, Cd, Co, Cr, Fe, Mn, Ni, O, Pb, S, Sb, Se, Si, Sn, Te and Zn, subject to the exclusion of any individual elements indicated.																		
8.2 MECHANICAL PROPERTIES: The mechanical properties shall conform to the appropriate requirements as per BS EN 13600 -2013 given in the table below:																		
<table border="1"> <thead> <tr> <th>Material condition</th> <th>Tensile Strength (R_m) N/mm²</th> <th>0.2% proof strength (R_{p0.2}) N/mm²</th> <th>Elongation A % (Min.)</th> </tr> </thead> <tbody> <tr> <td>R200</td> <td>200-250</td> <td>Max. 120</td> <td>35</td> </tr> </tbody> </table>						Material condition	Tensile Strength (R _m) N/mm ²	0.2% proof strength (R _{p0.2}) N/mm ²	Elongation A % (Min.)	R200	200-250	Max. 120	35					
Material condition	Tensile Strength (R _m) N/mm ²	0.2% proof strength (R _{p0.2}) N/mm ²	Elongation A % (Min.)															
R200	200-250	Max. 120	35															
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in any way detrimental to the interest of the company.	REV. NO. 5																	
INVENTORY NO. 2443	निर्माकृत WORKED BY SATENDER KUMAR		15-01-19		जांचकर्ता CHECKED BY AJAY KUMAR GUPTA													

संस्थान क्रय विनिर्देश (हीप : हरिद्वार) PLANT PURCHASE SPECIFICATION (HEEP: HARIDWAR)	HW12086											
	पृष्ठ 5 का 3	Page 3 of 5										
8.3 ELECTRICAL PROPERTIES (at 20° C): The electrical properties shall conform to the appropriate requirements as per BS EN 13600-2013 given in the table below:	<table border="1"> <thead> <tr> <th rowspan="2">Material condition</th> <th rowspan="2">Volume Resistivity (Max) $\Omega \times \text{mm}^2$ m</th> <th colspan="2">Conductivity</th> </tr> <tr> <th>MS/m (Min.)</th> <th>% IACS (Min.)</th> </tr> </thead> <tbody> <tr> <td>R200</td> <td>0.01724</td> <td>57.0</td> <td>98.3</td> </tr> </tbody> </table> <p>* IACS: International Annealed Copper Standard</p>		Material condition	Volume Resistivity (Max) $\Omega \times \text{mm}^2$ m	Conductivity		MS/m (Min.)	% IACS (Min.)	R200	0.01724	57.0	98.3
Material condition	Volume Resistivity (Max) $\Omega \times \text{mm}^2$ m	Conductivity										
		MS/m (Min.)	% IACS (Min.)									
R200	0.01724	57.0	98.3									
Determination of electrical conductivity should be carried out as per IS3635. Alternatively, the method of measurement employing Eddy current probes as per ASTM-E 1004 is also acceptable.												
8.4 DIMENSIONAL CHECK: Window dimensions of the hollow copper conductor is to be checked by shadowgraph method on the sample copper as mentioned in "selection of test sample" at serial no. 9 of this specification. Supplier has to supply a copy of shadowgraph along with test certificates, in support of dimensional accuracy of the window dimensions of the hollow copper conductor.												
8.5 TESTING FOR DOUBLING FREEDOM: - The sample will be cut from one tube taken randomly from every charge and test for flattening and doubling will be done as per IS:2501.												
8.6 TESTING FOR ERROR FREEDOM OF THE INNER SURFACE: - The flat pressed cutting or samples are to be cut in longitudinal direction for the proof of error freedom of tube inner surface and subjected to a visual inspection below the microscope.												
9. HYDROGEN EMBRITTLEMENT TEST: Hydrogen embrittlement test shall be performed on each finished tube. Testing should be as stipulated in EN ISO 2626 and EN13600.												
10. SELECTION OF TEST SAMPLES For the testing, a sample of approximately 3 meters is taken from every 500Kg and all the tests stipulated in the specification are to be conducted. If the results are not up to the stipulated standards as mentioned in this specification, a second sample of 3 meters is taken and all the tests has to be repeated. If the results are still not up to the standards set in, the whole lot of 500Kg is rejected.												
REV. NO. 5	निर्माणकर्ता WORKED BY SATENDER KUMAR	15-01-19										
जांचकर्ता CHECKED BY AJAY KUMAR GUPTA	15-01-19											

BHEL भारतीय विद्युत निर्माता संस्थान	संस्थान क्रय विनिर्देश (हीप : हरिद्वार)		HW12086	
	PLANT PURCHASE SPECIFICATION (HEEP: HARIDWAR)		पृष्ठ 5 का 4 Page 4 of 5	
SUPERSEDES INVENTORY NO.	11. TEST CERTIFICATES Three copies of test certificates on the obtained test results shall be supplied along with following information: - <ul style="list-style-type: none"> ➤ HW 12086 ➤ BHEL P.O. No. ➤ Size and Quantity ➤ Batch no. ➤ Supplier's Name. ➤ Certificate for electrical and mechanical properties. ➤ Certificate for chemical composition and hydrogen embrittlement test. ➤ Certificate for test for doubling freedom and error freedom. ➤ Certificate for Dimensional report along with window dimension of rectangular hollow copper conductor. ➤ Certificate for Grease freedom on inner surface. 			
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in any way detrimental to the interest of the company.	12. PACKING The tubes shall be suitably packed to prevent damage during transit. Each piece is to be legibly marked or labelled with the following information. <ul style="list-style-type: none"> i) Size ii) BHEL P.O. No. iii) Supplier's name iv) Length and weight of material in packing 			
स्वतंत्रतापूर्वक एवं गोपनीय इस दस्तावेज में दी गई जानकारी भारत भारी विद्युत निर्माता संस्थान की संपत्ति है। इसे किसी भी रूप में बिना अनुमति के प्रयोग नहीं किया जा सकता है।	13. REJECTION AND REPLACEMENT If the material does not comply with the requirements of this specification after receipt and inspection at BHEL or if any defects found during further processing. BHEL reserves the right to reject the whole consignment and supplier shall replace the material free of cost.			
निम्नलिखित मानक लागू होंगे BS EN 13600:2013 EN 1976 ISO 2626 IS 3635 ASTM E 1004 IS 2501	14. LIST OF CROSS REFERRED STANDARDS BS EN 13600:2013 EN 1976 ISO 2626 IS 3635 ASTM E 1004 IS 2501			
REV. NO. 5	निर्माणकर्ता WORKED BY		SATENDER KUMAR	15-01-19
जांचकर्ता INVENTORY 12-26-19	जांचकर्ता CHECKED BY		AJAY KUMAR GUPTA	15-01-19

दिनांक पर हस्ताक्षर SIGN & DATE		संस्थान क्रय विनिर्देश (हीप : हरिद्वार) PLANT PURCHASE SPECIFICATION (HEEP: HARIDWAR)	HW12086 पृष्ठ 5 का 5 : Page 5 of 5	
दिनांक पर हस्ताक्षर SIGN & DATE	SUPERSEDES INVENTORY NO.			
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in any way detrimental to the interest of the company.	रजिस्ट्रार के पास रखी जाएगी To be kept in the Registrar's Office	$r1 = 1.3 \text{ TO } 1.6$ $r2 = 0.5 \text{ TO } 0.8$ Wt. in Kg./Meter = 7 Cross Section in $\text{mm}^2 = 790.7$ <u>BARE RECTANGULAR COPPER CONDUCTOR</u>		
इस दस्तावेज़ में दी गई जानकारी केवल सूचना के लिए है। इसका उपयोग किसी भी प्रकार से नहीं किया जाना चाहिए। This document contains information for reference only. It should not be used for any purpose.	रजिस्ट्रार के पास रखी जाएगी To be kept in the Registrar's Office	FIGURE -1		
दिनांक पर हस्ताक्षर SIGN & DATE 24/1/19	REV. NO. 5		निर्माणकर्ता WORKED BY SATENDER KUMAR	15-01-19
दिनांक पर हस्ताक्षर SIGN & DATE P-2463			जांचकर्ता CHECKED BY AJAY KUMAR GUPTA	15-01-19